

Government of Bihar
Public Health Engineering Department
Water Quality Report

District:- Nawada **Division Name:- Public Health Engineering Division, Nawada**

Sample Code:-DL/NWD/94

Sample Collected by:- Gyanoday Vidyalaya, Kashichak ((Kunal Gautam)						Date of Sampling :- 07-04-2025											
Sl. NO.	Block	Panchayat	Village	Name of School	Scheme	Test Report										Source of water	Remarks
						pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	ALK	F		
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
1	Kashichak	Kashichak	Tilak Nagar, Shahpur more	Gyanoday Vidyalaya, Kashichak	Tubewell	7.21	0.62	471	305	140	48	4.8	35	130	0.52	(Tap Water)	Tested Parameters are within Permissible Limit.
Desirable Limit* (IS10500:2012)						6.5	1.0	500	500	200	75	30	250	200	1.0		
Permissible Limit* in absence of alternate						8.5	5.0	2000	2000	600	200	100	1000	600	1.5		

[Signature]
11/4/2025
Chemist

P.H. Division, Nawada

[Signature]
11/4/25

Assistant Engineer
P.H. Sub, Division, Nawada

[Signature]
11/4/25

Executive Engineer
P.H. Division, Nawada

