

**Government of Bihar**  
**Public Health Engineering Department**  
**Water Quality Report**

District:- Nawada

Division Name:- Public Health Engineering Division, Nawada

Sample Code:- 890

Sample Collected by:- Gyanoday Vidyalaya, Kashichak ((Kunal Gautam)						Date of Sampling :- 24-06-2024										
Sl. NO.	Block	Panchayat	Village	Name of School	Scheme	Test Report										Source of water
						pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	ALK	F	
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17
1	Kashichak	Kashichak	Tilak Nagar, Shahpur more	Gyanoday Vidyalaya, Kashichak	Tubewell	7.14	0.48	456	295	200	44	21.6	40	210	0.43	(Tap Water)
Desirable Limit*						6.5-8.5	1.0	500	500	200	75	30	250	200	1.0	
Permissible Limit* in absence of alternate source						NR	5.0	2000	2000	600	200	100	1000	600	1.5	
Remarks:-																

*(Signature)*  
15/07/2024  
Chemist

P.H. Division, Nawada

